

**MONTHLY SUMMARY OF DISTRIBUTION SYSTEM COLIFORM MONITORING**  
**(including triggered source monitoring for systems subject to the Groundwater Rule)**

System Name <b>Mount Baldy Community</b>	System Number <b>3610033</b>
Sampling Period <b>February</b>	Year <b>2023</b>

	Number Required	Number Collected	Number Total Coliform Positives	Number Fecal/E.coli Positives
1. Routine Samples (see note 1)	<b>1</b>	<b>1</b>	<b>0</b>	<b>0</b>
2. Repeat Samples following Samples that are Total Coliform Positive and Fecal/E.coli <b>Negative</b> (see notes 5 and 6)	<b>0</b>	<b>0</b>		<b>0</b>
3. Repeat Samples following Routine Samples that are Total Coliform <b>Positive</b> and Fecal/E.coli Positive (see notes 5 and 6)	<b>0</b>		<b>0</b>	<b>0</b>
4. MCL Computation for Total Coliform Positive Samples				
a. Totals (sum of columns)		<b>1</b>	<b>0</b>	
b. If 40 or more samples collected in month, determine percent of samples that are total coliform positive [ $(\text{total number positive}/\text{total number collected}) \times 100$ ] =				%
c. Is system in compliance... ...with fecal/E. coli MCL? (see notes 2 and 3)	Yes	No		
...with monthly MCL? (see note 4)	Yes	No		
5. Source Samples Triggered by Routine Samples that are Total Coliform Positive (This applies <b>only</b> to systems subject to the Groundwater Rule - see notes 7 and 8)		<b>0</b>	<b>0</b>	<b>0</b>
6. Invalidated Samples (Note what samples, if any, were invalidated; who authorized the invalidation; and when replacement samples were collected. Attach additional sheets, if necessary.)				
7. Summary Completed By:				

Signature	Title	Date
	Operator T2,D3	2/9/23

## NOTES AND INSTRUCTIONS:

1. Routine samples include:
  - a. Samples required pursuant to 22 CCR Section 64423 and any additional samples required by an approved routine sample siting plan established pursuant to 22 CCR Section 64422.
  - b. Extra samples are required for systems collecting less than five routine samples per month that had one or more total coliform positives in previous month;
  - c. Extra samples for systems with high source water turbidities that are using surface water or groundwater under direct influence of surface water and do not practice filtration in compliance with regulations;
2. Note: For a repeat sample following a total coliform positive sample, any fecal/E.coli positive repeat (boxed entry) constitutes an MCL violation and requires immediate notification to the Division (22 CCR, Section 64426.1).
3. Note: For repeat sample following a fecal/E.coli positive sample, any total coliform positive repeat (boxed entry) constitutes an MCL violation and requires immediate notification to the Division (22 CCR, Section 64426.1).
4. Total coliform MCL (Notify the Division within 24 hours of MCL violation):
  - a. For systems collecting less than 40 samples, if two or more samples are total coliform positive, then the MCL is violated.
  - b. For systems collecting 40 or more samples, if more than 5.0 percent of samples collected are total coliform positive, then the MCL is violated.
5. Positive results and their associated repeat samples are to be tracked on the Coliform Monitoring Worksheet.
6. Repeat samples must be collected within 24 hours of being notified of the positive results. For systems collecting more than one routine sample per month, three repeat samples must be collected for each total coliform positive sample. For systems collecting one or fewer routine samples per month, four repeat samples must be collected for each total coliform positive sample.
7. For systems subject to the Groundwater Rule: Positive results and the associated triggered source samples are to be tracked on the Coliform Monitoring Worksheet.
8. For triggered sample(s) required as a result of a total coliform routine positive sample, an *E.coli*, enterococci, or coliphage positive triggered sample (boxed entry) requires immediate notification to the Division, Tier 1 public notification, and corrective action.

10/2009 - 84 / 7

# Clinical Laboratory of San Bernardino, Inc.

Celebrating 50 Years of Analytical Service 1967-2017



**Client:** Choice Water Solutions  
8424 Santa Monica Blvd Ste 291  
West Hollywood CA, 90069

**Contact:** Ron Capotosto  
**Phone:** (760) 427-0603  
**Fax:**  
**System:**

**Project:** Mt. Baldy HOA

**Sub Project:**

**Sampler:** Ron Capotosto  
**Sampled:** 02/03/23

**Received:** 02/03/23 13:30

**Reported:** 02/08/23

## RESULTS

Laboratory	Sample	Sample	Cl Res (Field)	Total Coliform	E. Coli
ID	Time	Location	mg/L	P/A	P/A
23B0462-01	11:45	Bear Creek Spring		A	A
23B0462-02	12:30	Mt Baldy Lodge	0.55	A	A

A Absence of Bacteria

P Presence of Bacteria

**Bridget Durand**

Project Manager

四

**Clinical Lab of San Bernardino, Inc.**  
21881 Barton Road Grand Terrace CA 92313 909 825-7761

**Chain of Custody**  
N 8th St. Lompoc CA 93436 805 737-7300

三、第3、53、111頁